



Notice is hereby given that the
Eastern Summit County Sewer Advisory Committee (ESAC)
will meet
electronically, via zoom, on
Thursday, August 27, 2020
8:30 a.m.

AGENDA

1. Public input not on the agenda
2. Discussion regarding best practices for Large Underground Waste Water Treatment Systems.

Please click the link below to participate in the Zoom Meeting:

<https://summitcountyut.zoom.us/j/93276632774?pwd=WU9MQ1RldGs3TVN5cjBJSmM1UIQxQT09>

To listen by phone dial:

US: +1 669 900 9128 or +1 346 248 7799

Zoom Meeting ID: 932 7663 2774

Password: 704993

Individuals with questions, comments, or needing special accommodations pursuant to the Americans with Disabilities Act regarding this meeting may contact Melissa Hardy in the Community Development Department at (435) 336-3157.

Posted: August 21, 2020

Published: August 21, 2020-The Summit County News

ESAC community system requirements.

- House to tank
 - Minimum 4" line.
 - Minimum 1 cleanout
 - Additional cleanout every 100' and 180 degree directional change
 - Minimum 2% slope
 - 90's not allowed
- Tank
 - Minimum 1000 gal tank. Size based on number of bedrooms
 - 4' maximum bury. Pumping may be necessary to accomplish this
 - If homeowner owns the tank do we care about where tank is located? Example would be gravity out of the house to the tank behind the house then pump to the sewer system.
 - Effluent filters required with access to surface over the filter.
 - Minimum number of access ports over tank?
 - Concrete required? Or will we Allow poly
 - Certified installer?
- Tank to community collection
 - Minimum 2% slope
 - Minimum 4" pipe for gravity
 - Pump systems may use smaller pipe
 - Minimum 4' bury if pressurized or allow backflow to tank. If so inlet into manholes will need to be above flood rim.